

BONDING AND GROUNDING COMPRESSION LUGS



The Compression Lugs terminate copper or tinned-copper conductors for connection to busbars, cabinets, racks, and cable runway. They are color-coded by conductor size. Installation of the Compression Lugs requires two screws (not included).

FEATURES

The Compression Lugs terminate copper or tinned-copper conductors for connection to busbars, cabinets, racks, and cable runway.

They are color-coded by conductor size. Installation of the Compression Lugs requires two screws (not included).

SPECIFICATIONS

Table 1/2

Catalog Number	Article Number	Cable Size	On-Center Dimension Between Holes	Required Screw Size	Finish	Material
DGCL201	17256	#2/0	1in	3/8	Electroplated, Tinned	Copper
DGCL21	17254	#2	0.625in	1/4	Electroplated, Tinned	Copper
DGCL22	17255	#2	1in	3/8	Electroplated, Tinned	Copper
DGCL402	17257	#4/0	1in	3/8	Electroplated, Tinned	Copper
DGCL61	17252	#6	0.625in	1/4	Electroplated, Tinned	Copper
DGCL62	17253	#6	1in	3/8	Electroplated, Tinned	Copper

Table 2/2

Catalog Number	Article Number	Thickness
DGCL201	17256	0.14in
DGCL21	17254	0.14in
DGCL22	17255	0.14in
DGCL402	17257	0.14in
DGCL61	17252	0.14in
DGCL62	17253	0.14in

WARNING

nVent products shall be installed and used only as indicated in nVent's product instruction sheets and training materials. Instruction sheets are available at www.nvent.com and from your nVent customer service representative. Improper installation, misuse, misapplication or other failure to completely follow nVent's instructions and warnings may cause product malfunction, property damage, serious bodily injury and death and/or void your warranty.



Our powerful portfolio of brands:
nVent.com CADDY ERICO HOFFMAN RAYCHEM SCHROFF
TRACER