5.1mm .20in

UDF12C800AL 569208



IEC 60947-7-1

IBSB: 800 A FLEX: 885 A 1000 VAC / 1500 VDC Uimp = 12kV; lpk = 73.5 kA


Icw kA rms 1s = 42.9



UL 1953 1000 V AC/DC SCCR up to 100kA*

AL or CU Conductor 95% Fill Ratio Halogen Free UL 94 V-0

0




136.0mm

5.36in

55.2mm 2.17in

For voltage measurement only. 6-32 UNC-2B 9 in-lbs [1.0 N-m] 4 mm² / 12 AWG max

35.9mm [1.41in]



IEC 60947-7-1												
	No. Terminals	Conductor	Size	Ø DIA	Torque	Strip Length	Hex					
	1	ERIFLEX FLEXIBAR** [ERIFLEX IBSB]	2X20X1 to 10X32X1 [50 to 240 mm ²]	N/A	42.2 N-m	62.2 mm	10 mm					
	12		4 mm² to 25 mm²	6.9 mm	11.3 N-m	15.9 mm	4 mm					

UL 1953											
	No. Terminals	Conductor	Size	Ø DIA	Torque	Strip Length	Hex				
	1	ERIFLEX FLEXIBAR** [ERIFLEX IBSB]	2X20X1 to 10X32X1 [50 to 240 mm²]	N/A	375 in-lbs	2.45 in	3/8 in				
	12		12 AWG to 4 AWG	0.272 in	100 in-lbs	0.625 in	5/32 in				

NOTE:

- *Refer to UL file E497276. 1.
- 2. **Includes ERIFLEX FLEXIBAR Advanced
- 3. For multiple phase assemblies, join blocks together before installing onto DIN profile.
- 4. When mounted on DIN profile, end stops should be used on both ends of gangable blocks.
- For IEC, the cable must be secured within 15 cm of the terminal. 5.

- RNING:

 Nent products shall be installed and used only as indicated in nVent product instruction sheets and training materials. Instruction sheets are available at www.nVent.com and from your nVent customer service representative.

 NVent products must never be used for a purpose other than the purpose for which they were designed or in a manner that exceeds specified load ratings. All instructions must be www.nVent/sommons.org/left-by-followed-to-ensure-proper and safe installation, and warnings may cause product malfunction, properly damage, serious bodily injury and/or death, and void your warranty.

SAFELY INSTRUCTIONS:
All governing codes and regulations and those required by the job site must be observed.
All governing codes and regulations and those required by the job site must be observed.
Always use appropriate safety equipment such as eye protection, hard hat, and gloves as appropriate to the application.

NVent, nVent CADDY, nVent ERICO Cadweld, nVent ERICO Critec, nVent ERICO, nVent ERIFLEX, and nVent LENTON are owned by nVent or its global affiliates. All other trademarks are the property of their respective owners. nVent reserves the right to change specifications without prior notice.

TECHNICAL RIPPORT

